

Declaration of Performance



DoP reference number : CPR-1020

- 1, Unique Identifier : U/UTP
- 2, Intended use : Supply of communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- 3, Contact address : Belcom Cables Ltd
Green Street,
Elsenham,
CM22 6DS
- 4, System of evaluation of AVCP : System 3
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : 0832 - BRE GLOBAL
- 7, Declared Performances :

| Essential Characteristics | AVCP | Performance | Harmonized technical specification |
|---------------------------|----------|-------------|------------------------------------|
| Reaction to fire | System 3 | Eca | EN 50575:2014 + A1:2016 |
| Dangerous substances | | None | |

- 8, The performance of the product identified above is in conformity with the set declared performances.
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.

| Test method & test report number. | Parameter | No. test runs | Results | |
|---------------------------------------|-----------|---------------|---------------------------------|--|
| | | | Continuous parameter - mean (m) | Compliance with parameters Criterion for E |
| EN 60332-1-2 P107455-1078 Issue: 1 | H | 1 | 115,5 mm | H < 425mm / Compliant |

Signed for and on behalf of the manufacturer by:

HSEQ Manager :

M. Dobson :

Director :

K. Ewing