

Declaration of Performance



DoP reference number : CPR-1042

- 1, Unique Identifier : RG174 AU-ZH
- 2, Intended use : 50 OHM RF Coaxial Cable to be used in buildings and civil works with the aim of limiting the production and spread of fire and smoke
- 3, Contact address : SIVA S.R.L.
- 4, System of evaluation of AVCP : System 3
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : IMQ-0051
- 7, Declared Performances :

Essential Characteristics	AVCP	Performance	Harmonized technical specification
Reaction to fire	System 3	Eca	EN 50575:2014 + A1:2016
Dangerous substances		None	

- 8, The performance of the product identified above is in conformity with the set declared performances.
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

HSEQ Manager :

M. Dobson:

Director :

K. Ewing

UK Declaration of Conformity



DoP reference number : CPR-1042

- 1, Unique Identifier : RG174 AU-ZH
- 2, Intended use : 50 OHM RF Coaxial Cable to be used in buildings and civil works with the aim of limiting the production and spread of fire and smoke
- 3, Contact address : SIVA S.R.L.
- 4, System of evaluation of AVCP : See page 1
- 5, Harmonized standard : BS EN 50575:2014 + A1:2016
- 6, Declared Performances : For results see page 1
- 7, The performance of the product identified above is in conformity with the set declared performances.
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.



Signed for and on behalf of the manufacturer by:

HSEQ Manager :

M. Dobson:



Director :

K. Ewing

