

# Declaration of Performance



DoP reference number : CPR-1071

- 1, Unique Identifier : L45467-F16-W6
- 2, Intended use : Supply of communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- 3, Contact address : Belcom Cables Ltd  
Green Street,  
Elsenham,  
CM22 6DS
- 4, System of evaluation of AVCP : System 3
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : 0832 - BRE GLOBAL
- 7, Declared Performances :

| Essential Characteristics | AVCP     | Performance | Harmonized technical specification |
|---------------------------|----------|-------------|------------------------------------|
| Reaction to fire          | System 3 | Eca         | EN 50575:2014 + A1:2016            |
| Dangerous substances      |          | None        |                                    |

- 8, The performance of the product identified above is in conformity with the set declared performances.  
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.

| Test method & test report number.     | Parameter | No. test runs | Results                         |  |
|---------------------------------------|-----------|---------------|---------------------------------|--|
|                                       |           |               | Continuous parameter - mean (m) | Compliance with parameters Criterion for E |
| EN 60332-1-2 P111783-1011<br>Issue: 1 | H         | 1             | 93 mm                           | H < 425mm /<br>Compliant                   |

Signed for and on behalf of the manufacturer by:

HSEQ Manager :

M. Dobson :

Director :

K. Ewing