

Declaration of Performance



DoP reference number : CPR-1090

- 1, Unique Identifier : FireFighter-400-Dca
- 2, Intended use : Supply of communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- 3, Contact address : Belcom Cables Ltd
Green Street,
Elsenham,
CM22 6DS
- 4, System of evaluation of AVCP : System 3
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : 0832 - BRE GLOBAL
- 7, Declared Performances :

Essential Characteristics	AVCP	Performance	Harmonized technical specification
Reaction to fire	System 3	Dca	EN 50575:2014 + A1:2016
Dangerous substances		None	

- 8, The performance of the product identified above is in conformity with the set declared performances.
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.

Test method & test report number.	Parameter	No. test runs	Results	
			Continuous parameter - mean (m)	Compliance with parameters Criterion for E
EN 60332-1-2 P111954-1005 Issue: 1	H	1	117,5 mm	H < 425mm / Compliant

Test Method	Result
EN 50399:2011+A1:2016 P111954-1003/1004	Dca-S2-D2-A1

Signed for and on behalf of the manufacturer by:

HSEQ Manager
M. Dobson :

Director :
K. Ewing