

Declaration of Performance



DoP reference number : CPR-1085

- 1, Unique Identifier : 40 Series 0,6/1 kV
- 2, Intended use : Flexible cable for control and/or transport of energy with the objective of limiting the generation and spread of fire and smoke.
- 3, Contact address : Belcom Cables Ltd
Green Street,
Elsenham,
CM22 6DS
- 4, System of evaluation of AVCP : System 3
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : 0370 - Applus
- 7, Declared Performances :

| Essential Characteristics | AVCP | Performance | Harmonized technical specification |
|---------------------------|----------|------------------|------------------------------------|
| Reaction to fire | System 3 | B2ca-S1b, d0, a1 | EN 50575:2014 + A1:2016 |
| Dangerous substances | | None | |

- 8, The performance of the product identified above is in conformity with the set declared performances.
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

HSEQ Manager :

M. Dobson:

Director :

K. Ewing