

Declaration of Performance



DoP reference number : CPR-1114

- 1, Unique Identifier : DATA, CONTROL CABLES HFFR, 4BSERIES
- 2, Intended use : Supply of communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- 3, Contact address : Belcom Cables Ltd
Green Street,
Elsenham,
CM22 6DS
- 4, System of evaluation of AVCP : System 1+
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : 2184 Efectis
- 7, Declared Performances :

Essential Characteristics	AVCP	Performance	Harmonized technical specification
Reaction to fire	System 3	B2ca, s1a, d1, a1	EN 50575:2014 + A1:2016
Dangerous substances		None	

- 8, In case of the declaration of performance concerning a construction product covered by a Harmonized Standard:
Notified product certification body no. 2184 performed the determination of product type, the initial inspection of the manufacturing plant and FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy performance.
- 9, The performance of the product identified in point 1 is in conformity with the declared performance in point 7. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

Signed for and on behalf of the manufacturer by:

HSEQ Manager
M. Dobson :

Director :
K. Ewing

UK Declaration of Conformity



DoP reference number : CPR-1114

- 1, Unique Identifier : DATA, CONTROL CABLES HFFR, 4BSERIES FireFighter-400-Dca
- 2, Intended use : Supply of communication in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- 3, Contact address : Belcom Cables Ltd
Green Street,
Elsenham,
CM22 6DS
- 4, System of evaluation of AVCP : System 3
- 5, Harmonized standard : EN 50575:2014 + A1:2016
- 6, Notified agency : 0832 - BRE GLOBAL
- 7, Declared Performances :

Essential Characteristics	AVCP	Performance	Harmonized technical specification
Reaction to fire	System 3	Dca	EN 50575:2014 + A1:2016
Dangerous substances		None	

- 8, The performance of the product identified above is in conformity with the set declared performances.
This declaration of performance is issued , in accordance with Regulation (EU) no 305/2011, under the sole responsibility of the manufacturer identified above.

Test method & test report number.	Parameter	No. test runs	Results	
			Continuous parameter - mean (m)	Compliance with parameters Criterion for E
EN 60332-1-2 P111954-1005 Issue: 1	H	1	117,5 mm	H < 425mm / Compliant

Test Method	Result
EN 50399:2011+A1:2016 P111954-1003/1004	Dca-S2-D2-A1

Signed for and on behalf of the manufacturer by:

HSEQ Manager
M. Dobson :

Director :
K. Ewing